

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160719-S1871  
**Report Reference** S1871-19990210  
**Issue Date** 2016-JULY 19

**Issued to:** Bosch Security Systems Inc  
130 Perinton Pkwy  
Fairport NY 14450-9107

**This is to certify that  
representative samples of**

Fire and Security Equipment:  
Digital Alarm Communicator Receiver, Model D6600.

Fire and Security Subassemblies:  
Models D6610 CPU Card, D6615 Communication  
Terminator Card  
D6641 Line Card,  
D6645 Line Terminator Card  
D6672 COM1 expansion card,  
D6690 Line Card,  
D6691 Expansion Card and  
D6695 Terminator Card.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See addendum page  
**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160719-S1871  
**Report Reference** S1871-19990210  
**Issue Date** 2016-JULY 19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Standards for Safety:

UL 864 - Standard for Control Units for Fire Protective Signaling Systems, Ninth Edition,  
UL 365 – Standard for Police Station Connected Burglar Alarm Units  
UL 1076 – Proprietary Alarm Units  
ULC/ORD-C1076 – Proprietary Burglar Alarm Units  
UL 1610 – Central Station Burglar Alarm Units

CAN/ULC-S303 – First Edition, dated May 1991 – Local Burglar Alarm Units and Systems  
CAN/ULC-S304-06, Second Edition, dated July 2006 – For Signal Receiving Centre and  
Premise Burglar Alarm Control Units,

Model D6600 – ULC-S559 - Standard for Equipment for Fire Signal Receiving Centres and  
Systems

For use with Sonitrol products only:

CAN/ULC-S319-05, Edition 1, dated September 2005 – For Electronic Access Control Systems  
UL 294, Edition 5, dated September 17, 2010 – Standard for Access Control System Units.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

