

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-1615:0179

Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450  
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263  
Email: jon.wolski@us.bosch.com

**DESIGN:** Model D6600 Netcom Digital Alarm Communication Receiver (DACR). Unit is intended for receiving alarm signals in a central monitoring station. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

- D6600; Receiver
- D6610; CPU Card
- D6615; CPU Terminator Card
- D6630; AC/DC Power Supply Module
- D6631; DC/DC Power Supply Module
- D6640; Telephone Line Card
- D6641; Line Card
- D6645; Telephone Line Terminator Card
- SC9002; External Printer
- D6680-E120; Network Adaptors
- D6672; Com 1 Expansion Module
- ITS-D6882-UL and \*ITS-D6686-UL; Ethernet Network Adapters

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as digital alarm communication receiver for use with listee's separately listed Model C900TTL-E Dialer Capture Module and D9133TTL-E Network Interface Module (CSFM Listing No. 7300-1615:180) and Models D7212, D7412, D9112, D9412, D7412G, D9412GV2\*, D7412GV2\*, or D9412G fire alarm control units. D6600 may also be used with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

\*Rev. 01-30-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2012**

Listing Expires **June 30, 2013**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**  
*Fire Engineering Division*