

消 防 處
牌 照 及 審 批 總 區
香 港 九 龍 尖 沙 咀 東 康 莊 道 1 號 5 樓
消 防 總 部 大 廈



**FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION
COMMAND**

FIRE SERVICES HEADQUARTERS BUILDING,
5/F, No.1 Hong Chong Road,
Tsim Sha Tsui East, Kowloon,
Hong Kong.

本處檔號 OUR REF.:(37) in FP 206/1192
來函檔號 YOUR REF.: J-005/C/023
電報掛號 TELEX:39607 HKFSD HX
電子郵件 E-mail : <lcpolice2@hkfsd.gov.hk>
圖文傳真 FAX: 852-2367 3631
電 話 TEL NO.: 2733 7744

18 June 2003

Bosch Security Systems Ltd.
12/F, Metropole Square,
2 On Yiu Street,
Shatin, NT

Dear Sirs,

Acceptance of Smoke Detector

I refer to my interim reply of 22.4.2003 on the captioned subject.

Please be informed that the following detectors, which were certified by Underwriters Laboratories Inc., are acceptable to this Department:-


- Manufacturer** : Radionics Div of Detection Systems Inc.
(basically listed for Detection System, Inc.)
- Type** : Smoke – Automatic Fire Detector, Photoelectric Type
- Models** : i) D263 Series
D263C, D263S, D263THS
- ii) D273 Series
D273S, D273THS, D273X,
D273THX, D273R, D273THR,
D273NS, D273N, D273I,
D273C, D273THC, D273IS,
D273CS, D273THCS, D273SR,
D273THSR, D273THE, D273ES,
D273Y, D273THES
- Testing Standard** : UL 268, Smoke Detectors for Fire Protective Signaling Systems
- Supporting Documents** : i) Test Report File S3019 Project 93NK5284 issued by UL on 1.10.1993 and last revised on 2.10.2001
- ii) Multiple Listing File No. S4992 issued by Underwriters Laboratories Inc. on 1.4.1996 and last revised on 22.4.2002

.../P2

Please note that the above acceptance is subject to :

- i) all conditions as stipulated in the above-mentioned Test Report and Multiple Listing Correlation Sheet being complied with;
- ii) the installation conforming to FSD Circular Letter No. 1/2002, Rules for Fire Detection and Alarm Systems for Buildings; and
- iii) the components used in the installation being compatible.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'LAU Kwai-shan', with a large, sharp peak in the middle of the signature.

(LAU Kwai-shan)
for Director of Fire Services

LKS/TTW/lcm